

Library / Depot Lot

The Library / Depot lot is located kitty-corner from the main library and partially cantilevered over the railroad tracks of the Depot. There is a large public (upper) lot with a pay station kiosk. Accessible parking spaces have been designated. The pay station kiosk is currently located up on a curb, above the maximum reach range. There are also a lower and contract lots, currently accessible parking spaces have not been designated for those lots.

Parking- Library / Depot

Accessibility Review

Location JQP # / Item #	Solution / Comments	Qty	Unit Cost	Total Cost	Priority	Estimated Compl. Date	Person Responsible	Actual Compl. Date	Actual Cost
Parking- Quantity									
05A 16742	Stripe an appropriate number of accessible parking stalls and provide appropriate permanent signage. IBC 1106.1 <i>The appropriate number of accessible parking spaces have been designated in the upper lot. There are currently no parking spaces designated as accessible in the lower or contract lot.</i>	4	\$400	\$1,600	3				
Parking- Signs									
05E 16739	Relocate the sign identifying each designated accessible parking stall, so centered at the head end of the parking space and mounted 60"-66" above the floor (measured to the bottom of the sign). MN1341 502.7 <i>The signs are currently at 86". Photo 2.</i>	5	\$250	\$1,250	3				
Parking- Size									
05H 16740	Stripe to provide an accessible parking stall that is 8' wide with an adjacent 8' access aisle. It is preferred that the access aisle be located on the passenger side of the vehicle. MN 1341 502.4.2 <i>Currently 3 of the parking spaces have 9' wide aisles, the others have 6' wide aisles. Photo 3.</i>	1	\$150	\$150	3				
Pay Station									
14F 16741	Lower object(s) so the highest operable part is no higher than 48". ICC / ANSI 308 <i>The top control of the electronic pay station is currently at 54". Photo 1.</i>	1	\$50	\$50	3				
				Priority # 3 Total	\$3,050				



Photo 1: Relocate the pay station so the controls are located within reach range.



Photo 2: Lower the signs designating the accessible parking spaces to 60"-66" (measured to the bottom of the sign). Currently at 86".



Photo 3: Restripe to provide an 8' wide parking space with an 8' wide aisle (can be shared between 2 spaces).