



**Purchasing Division**  
*Finance Department*  
Room 120  
411 West First Street  
Duluth, Minnesota 55802

 218-730-5340  
 purchasing@duluthmn.gov

**Addendum 1**  
**Solicitation 20-99498**  
**Construct Riley Road Salt Shed**

This addendum serves to notify all bidders of the following changes to the solicitation documents:

Changes are identified in the attached document.

Please acknowledge receipt of this Addendum by checking the acknowledgment box within the [www.bidexpress.com](http://www.bidexpress.com) solicitation.

Posted: **August 6, 2020**

August 5, 2020

**City of Duluth  
Riley Road Salt Shed  
Bid #20-99498**

**Bid Opening: Thursday, August 13, 2020 at 2:00 PM**

**NOTICE TO BIDDERS**

The following addendum shall be appended to and shall become a part of the plans and specifications for the Riley Road Salt Shed, Duluth, Minnesota

This addendum supersedes and supplants all previous reference to similar items.

RW FERN ASSOCIATES INC.

---

**ADDENDUM #1**

- 1) Plan 1/S2.0 and Section 4/S2.0  
Delete center "T Panel" on each drawing. Interior to be one compartment.
- 2) Plan 1/S2.0  
Add one end wall concrete pier and foundation pad per detail 3/S2.0. Locate pier centered between Grid A.4 and A.6 along Grid 1.
- 3) Section 4/S2.0  
Minimum clearances from truss arch structure to ground as follows:
  - Sidewall: 23'-3" at inside face of 12' high perimeter walls.
  - Center: 48'-4" at center of peak.

END OF ADDENDUM