



Purchasing Division
Finance Department
Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum 1
Bid 21-0076
2021 DES Manhole Repairs

This addendum serves to notify all bidders of the following responses to submitted questions:

Q1. In the Manhole Detail sheet for this project, MH#530 doesn't have an approximate size given. All others have an approximate size provided. Is that information known?

A1. MH#530 Dimensions 125" long by 85" wide.

Q2. When are the start date & completion dates for this project? Can more than one site be worked on at a time?

A2. The start date is approximately April and the estimated completion date is October. These dates are not set – DES is willing to work with awarded contractor. More than one manhole can be worked on at once.

Q3. Is there a rebar schedule?

A3. The average rebar size used in 2020 was #4 8"-10" O.C.E.W.

In addition, bidders are asked to supply a current rate sheet. A section has been added to the Bid Express solicitation for this purpose.

Please acknowledge receipt of this Addendum by checking the acknowledgment box within the Bid Express solicitation.

Posted: January 20, 2021