



Purchasing Division
Finance Department
Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum 2
Solicitation 20-99714
Snow Emergency Route Sign Installation

This addendum serves to notify all bidders of the following changes to the solicitation documents:

The following question asked is answered below.

The City of Duluth is full of rock, and all sign poles may not be able to be driven to a dept of four feet. How will this condition be treated? By driving poles to rock depth and cutting down the base poles to the approximate 2 ½" above grade? Who will be responsible for poles damaged due to hitting rock if this becomes an issue. *Cobbles, boulders or bedrock may be encountered during the project. If rock is suspected, the contractor should use a test probe to find a suitable location within the locate area. If none are available, notify the project engineer for resolution.*

Please acknowledge receipt of this Addendum by checking the acknowledgment box within the www.bidexpress.com solicitation.

Posted: February 9, 2021