

CITY OF DULUTH COUNCIL CHAMBERS REMODEL
DULUTH, MINNESOTA

ADDENDUM NO. 3

The following Addendum shall be appended to and become part of the Plans and Specifications for City of Duluth Council Chambers Remodel – Duluth, Minnesota.

This Addendum supersedes and supplants all previous reference to similar items.

Architecture Advantage, LLP
1411 London Road
Duluth, Minnesota 55805

Addendum Item:

Architectural:

1. Eliminate LED lights at Corian backlit panels. Provide Horizontal Create-a-Light Quantum Series Flexible Strip Lighting by Consumers Choice Lighting or similar. Incandescent bulbs – 24V. To be provided at all four edges of each of the (6) panels at the Counselors Dais’.
2. Window sizes approximately: 10’-6” high x 8’-4” wide for window shades.

Changes to Specification:

9. **SECTION 122413** **ROLLER WINDOW SHADES**

- A. Modify Section 2.1 Item B below.
 - B. Front Shade Band Material: Vinyl coated polyester yarn woven into basketweave pattern; Sheerweave Series **PW4000** ~~PW4100, PW4400, or PW4800~~ as selected by Architect.
 1. Color: As selected by Architect from manufacturer’s full range.
- B. Modify Section 2.1 Item C below.
 - C. Rear Shade Band Material: Close woven fiberglass base textile with sun-resistant vinyl film bonded to each side, opaque with minimum tensile strength of 190 pounds for warp and 180 pounds for fill; SunBloc Series SB9000 ~~and SB9100~~.
- C. Modify Section 2.3 Item E below.
 - E. Remote Controls: Electric controls with NEMA ICS 6, Type I enclosure surface mounting. Integrated with owner’s Crestron control system. ***Provide two group controls to operate all shades simultaneously.***
Clarification: Crestron controls by owner.
- D. Clarification: Housing to be surface mounted at the head of the window.