

Purchasing Division Finance Department

Room 120 411 West First Street Duluth, Minnesota 55802



Addendum #1 Solicitation # 22-99485 Project #2027 E 1st Street Sanitary Sewer Extension

This addendum serves to notify all bidders of the following changes to the solicitation documents:

SPECIAL PROVISIONS

Remove and **replace** with the following:

SP-19 (2503) PIPE SEWERS – GRAVITY

The provisions of 2503 are supplemented with the following:

Gravity sewer shall be installed by pipe bursting. Pipe material shall be 8" HDPE DIPS/IPS. SDR of the pipe shall be determined by the pipe bursting designer to meet the minimum strength requirements for the size and length of pull for the new pipe installation. No other material substitutions will be allowed without prior written permission from the project engineer.

Add the following:

SP-21 EXISTING SEWER FLOWS

Contractor is responsible for coordination and bypassing of any sewer flows in the existing sewer lines during the installation of the new sanitary pipe or structures. There is one known lateral connection upstream from the location of the proposed manhole structure in Superior Street (2 North Hawthorne Rd).

Please acknowledge receipt of this Addendum by checking the acknowledgment box within the www.bidexpress.com solicitation.

Posted: June 8, 2022