



Purchasing Division
Finance Department
Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum 3
Solicitation 22-99533
Lincoln Park Site Improvements

This addendum serves to notify all bidders of the following changes to the solicitation documents:

1. The BID DEADLINE has been EXTENDED to Wednesday, August 3, 2022 at 2:00 pm.
2. The attached document provides additional clarification on fencing requirements.

Please acknowledge receipt of this Addendum by checking the acknowledgment box within the www.bidexpress.com solicitation.

Posted: **August 1, 2022**



ADDENDUM NO. 03, AUGUST 1, 2022

RE: Lincoln Park Site Improvements

LHB Project No. 170032

To: All Planholders

From: LHB, Inc.

This Addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated July 5, 2022 as well as Addendum No. 01, dated July 22, 2022, and Addendum No. 02, dated July 27, 2022. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject the Bidder to disqualification.

This Addendum consists of 1 page:

Questions and Answers

Q1. Please clarify the following:

- i) The fence specs note that line posts are to be 1.9" (1-7/8") and corner/end posts are to be 2.38" (2-3/8"). This is typical for the height of this fence per MN DOT standard plate # 9322K specification reference # 2557. Fence detail sheet S1.02 detail 7 conflicts with this and notes 2-1/2" nominal diameter posts (assuming this applies to both line & corner/end posts as it does not clarify this). Fence detail also shows a 2" nominal diameter top rail (top rail is only available in 1-5/8" size). Please note that fence posts are typically not measured by nominal size but rather outer diameter similar to what is shown in the specs. Fence spec notes bottom tension wire. Please confirm this is the case as fence detail 7 looks like there is a bottom rail.
- ii) On sheet S1.02 note 2 it notes double extra strong pipe weights; 2" nominal diameter = 9.03 lbs/ft. Fence posts are not available in this weight. Please clarify.

A1. Refer to Sheet S1.02

- **Detail 6 – Base plate detail: Fence pipe to be per MnDOT specification 3362; 2" xx-strong.**
- **Detail 7 – Fence post and rail to be per MnDOT specification 3362; Post = 2 1/2" (nom.); Rail = 2" (nom.).**
- **Please note diameters are ID. Schedule 40 OD equivalent = 2 7/8" and 2 3/8"; Fy = 35 ksi or greater required.**

END OF ADDENDUM NO. 03