



Purchasing Division
Finance Department
Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum 3
Solicitation 22-99618
Brighton Beach Lakeshore Stabilization

This addendum serves to notify all bidders of the following changes to the solicitation documents:

Questions asked are answered in italics.

1. It was mentioned onsite, that excavated material was going to be used as fill for other locations on the site. Where is the material supposed to be placed? Should it be assumed in our proposal some of the excavated material is supposed to be hauled and disposed of off-site?

LHB addressed the placement of salvaged material in addendum 2. Good material will be stockpiled at the specified locations while asphalt and other poor materials will be removed from site.

2. If any scope of the project is not approved on September 12th as stated in the contract documents, how does that effect the start and completion dates of the project?

Start and end dates will be adjusted to accommodate for required work to be completed.

3. What are the acceptable extents for selective clearing of trees for the construction access on the Northeast entrance?

The City wishes to keep all vegetation along the trail as is possible. Overhead branches or leaning stems, that interfere with trucking, may be trimmed with City prior approval. Please set construction fence down the trail itself maintaining minimum 6 feet of the west side for trail use including fence bases and sandbags or other ballast. Trail bed occupied for construction access may be protected and restored after completion by covering with gravel, mats or other methods. Any damage to trail must be restored to original condition at end of construction. Asphalt plant closures should be factored in.

Please acknowledge receipt of this Addendum by checking the acknowledgment box within the www.bidexpress.com solicitation.

Posted: **08/26/2022**