



Purchasing Division
Finance Department
Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum 1
Solicitation 22-99418 2nd REBID
2nd REBID City Hall MEP Renewal (General Conditions Work Scope Only)

This addendum serves to notify all bidders of the following changes to the solicitation documents:

1. There is no plaster ceiling demo work in Open Office 314. All piping work for 4th radiation in this area will occur in the 4th floor ceiling space with piping drops along the exterior walls in each 4th floor office. Piping drops will be concealed using wall chases. Wall chases will be sized to also reroute existing electrical wiring currently mounted on the walls in each office.
2. There is an electrical contractor for the City Hall MEP Renewal project. The electrical contractor will provide all electrical services including the electrical raceway.
3. The general conditions work scope unit prices box item number 1 description had the word ceiling removed to reflect that plaster replacement is not limited to ceilings and could occur on a wall, soffit, or other plaster bearing surface.
4. The pre-bid meeting sign-in sheet is posted to BidExpress.

Please acknowledge receipt of this Addendum by checking the acknowledgment box within the www.bidexpress.com solicitation.

Posted: **9/26/22**