



**Purchasing Division**  
Finance Department  
Room 120  
411 West First Street  
Duluth, Minnesota 55802

218-730-5340  
purchasing@duluthmn.gov

**Addendum 1**  
**Solicitation 23-0002**  
**Hot Water Pipe Materials**

This addendum serves to notify all bidders of the following changes to the solicitation documents:

1. The bid deadline is extended to Wednesday, January 11, 2023 at 2:00 pm.

The following question is asked and answered below:

2. In the Bid Package #23-0002 for HWP Pipe Material Procurement Items List on page 8, and noted in RED below, line 31 states: 323/500MM WELDED LONG JOINT KIT. Please confirm if the LONG sleeve should be 850 or 1100mm wide?

*The long joint kits should be 850 mm wide minimum.*

Please acknowledge receipt of this Addendum by checking the acknowledgment box within the [www.bidexpress.com](http://www.bidexpress.com) solicitation.

Posted: **January 9, 2023**