



Purchasing Division
Finance Department
Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum 1
Solicitation 23-0285
Harborview Building Steam to Hot Water Conversion

This addendum serves to notify all bidders of the following changes to the solicitation documents:

Questions:

Is it acceptable to use copper propress system in lieu of solder or brazed fittings for hot water heating?

FTR units call for steel pipe with copper fins (cost and lead time concern). Is it acceptable to use a standard copper tube with aluminum fin in these locations?

Answer:

As long as the pipe and fittings are rated for our temps and pressures, it should be acceptable.

Please acknowledge receipt of this Addendum by checking the acknowledgment box within the www.bidexpress.com solicitation.

Posted: **April 3, 2023**