



**CITY OF DULUTH
PURCHASING DIVISION**

Room 100 City Hall
411 West First Street
Duluth, Minnesota 55802-1199
218/730-5340 218/730-5922 FAX

**ADDENDUM #1
10-16DS Gas Meter Relocating**

Please note that another pre-bid meeting is being held for the above project. Interested vendors are to meet at 5th Ave E and 4th Street Alley, SMDC at 9 AM June 8th.

The bid opening date has been moved to June 14th, 2 PM Room 100 City Hall.

The meter size of the first item listed is a 23M root with a 6" flange and not a 16M with a 4" flange.

There are no other changes to this bid.

Please note receipt of Addendum #1 on your bid or by returning a signed copy of the addendum.

Thank you.

Dennis Sears
Purchasing Agent

**RELOCATING AND PLUMBING OF MISC GAS METERS
FROM INSIDE TO OUTSIDE OF BUILDINGS, AT VARIOUS LOCATIONS.**

METER SIZE	FLANGES	REGULATOR	GASKETS	RELIEF	PIPING	LOCATION
ROOTS 23 M	6" STEEL FLAT FACE	2" 1098	4" FULL FACE	3" 63EG	APPROX 30' 4" WELDED	417 E 3 RD STREET
ROOTS 8C	2" STEEL FLAT FACE	2" 202	2" FULL FACE	2" 289H	APPROX 30' 2" B.I.	417 E 3 RD STREET
ROOTS 16 M	4" STEEL FLAT FACE	2" - 99	4" FULL FACE	2" 289H	APPROX. 20' 4" WELDED	222 N 2 ND AVE E
CITY TO SUPPLY ALL, WALL BRACKETS, METERS, REGULATORS, TEST POINTS, SHUTOFF VALVES AND RELIEFS						

WORK TO INCLUDE MOVING GAS METERS FROM INSIDE OF BUILDING TO OUTSIDE LOCATION,
INCLUDING ALL METER WORK AND GAS PIPING FROM RISER TO EXISTING INSIDE PIPING.

MANDATORY ATTENDANCE TO THE PRE BID MEETING