

ADDENDUM NO. 2
for
City of Duluth, Minnesota
Port Security RFP #10-24DS

August 23, 2010

This Addendum is to be included as part of the original proposal documents. The Proposer is bound but not limited to all requirements stated herein. As with the original Contract Documents, the Proposer is required to meet all applicable State and Federal building and installation codes including but not limited to ANSI/TIA/EIA, NEC, etc.

TO: ALL PROPOSERS OF RECORD

ADDENDUM NO. 2

This Addendum shall hereby be and become part of the Contract Documents the same as if originally bound thereto.

The following clarifications, amendments, additions, revisions, changes and modifications change the original Contract Documents only in the amount and to the extent hereinafter specified in this Addendum.

Each Proposer shall acknowledge receipt of this Addendum in its proposal response.

NOTE: Proposers are responsible for becoming familiar with every item of this Addendum.

A. DOCUMENT MODIFICATIONS AND CLARIFICATIONS:

1. **DELETE:** The City does not wish to go forward with the Alternate for the Bong and Blatnik Bridges. Therefore, DELETE references and response areas on: **Pages 20-21**, Section 00 21 16; **Page 37**, Section 00 42 00 item 1.04E; and **Appendix A** - lines 103-117. Proposers do not need to respond to this item. NOTE: the Response Form provided in MS Word already has these items removed.
2. **ADD:** Contractor shall provide and install one (1) new extra-deep equipment cabinet in the Lakewood Treatment Telecom Room to house new Server/Storage Appliance. Cabinet shall be Chatsworth 12419-736 with 12804-701 (fan kit) & 12820-707 (power strip). Add the cost of these items into your overall Base Proposal cost.
3. **DELETE:** Page 124, Section 28 23 13, item 2.06.W.5: DELETE this entire passage: “The system shall support the MxPEG video compression algorithm, which is unique to Mobotix. MxPEG encoding shall have the capability to maintain high image quality for megapixel cameras while dramatically decreasing bandwidth consumption”
4. **ADDITIONAL INFORMATION:** A copy of the Vendor Sign-In sheet is appended to this Addendum.

B. QUESTIONS AND ANSWERS:

- Q1.** Number 5 on page 21 – Intransa as an approved alternate... What Intransa platform has been approved?
- A1.** The design is based on the Pivot3 RAID 6e solution. We would also accept an equivalent Intransa solution as stated in the spec, but the proposer is required to follow the product substitution requests as detailed in the RFP so we could ensure the proposed Intransa solution meets/exceeds the specified Pivot3 solution.
- Q2.** Can you please provide Section 00 42 00 Proposal Form and Appendix A in word form so that it can be edited for submittal?
- A2.** A response form in Microsoft Word format will be sent to Proposers along with this Addendum, and it will also be posted on the City’s website.

END OF ADDENDUM NO. 2

Duluth Port Security Pre-Proposal Meeting - 8/19/2010

COMPANY	NAME	PHONE	EMAIL
ALL STATE COMMUNICATIONS	JEFF JUNGERS	320.309.4592	jeff@allstatecom.com
Jeff Halbert			
VTI Security	Jeff Halbert	952-707-9521	jeff.halbert@vtisecurity.com
MEGCOM	BERNIE SERRE	218-723-1413	bernie_serre@mesaba.com
TAPCO	KEVIN ALBERTSON	414-891-1899	KEVIN@TAPCOelectric.com
Per Ma-Security	Kevin Lloyd	218-722-1630	klloyd@per-mar-security.com
Per Mar Security	Eric Brandenburg	218-722-1630	ebrandenburg@per-mar-security.com
ADVANTAGE SYSTEMS corp	SCOTT EASTMAN	715-394-5509	ASG@ADVANTAGE-SYSTEMS.COM
PARSONS BRINCKER	TYLER WACHSTER	763-528-7744	TWACHSTER@PARSONSCORP.COM
Parallel Technologies	Tom Herr	952-278-0337	therr@ptnet.com
Parallel Tech	Tony Klein	952-278-0356	tklein@ptnet.com
PARAGON SOLUTIONS	Chris Dyr	763-463-3700	chris.dyr@paragon.net
PARAGON SOLUTIONS	Tom Foxa	763-463-3761	tom.foxa@paragon.net
EPITechnologies DALLMEIER	MIKE SARTON	847-395-1776	mikes@EPITECHNOLOGIES.COM
Dennis Painter			
AISG	Dennis Painter	218-390-1967	dpainter@aisg-online.com
Dennis Painter			
SIMPLEX GRINNELL	DENIS KLETTER	612-868-6834	DKLETTER@SIMPLENGRINNELL.COM
PROTECTDESIGN	Doug Buttan	218-839-1500	ddbattan@protectdesign.com
Scientel Wireless LLC	Randy Swets	630-652-3824	rswets@scientelwireless.com
MCD Solutions	James D Lee	218-529-2517	jlee@mcdsolutions.biz
MCD Solutions	Adam Creso	218-740-0554	cresoadam@jmi.li.com
AmioBMS Group	Joe Leland	320 492-3380	JLeland@AMIOGROUP.COM
ELECTRIC SYSTEMS	DAVE MICHALSKI	218 722 0964	CONTACT@ELECTRICSYSTEMS.COM

