



**CITY OF DULUTH
PURCHASING DIVISION**

Room 100 City Hall
411 West First Street
Duluth, Minnesota 55802-1199
218/730-5340 218/730-5922 FAX

**Addendum #1
10-20DS Garfield Storage Building**

This addendum serves to provide answers to a couple of question asked. Please return a copy of the addendum with your bid.

Q: There are two different building notes. One states 2 x 6 walls are to be 16” center and another states 24” centers. Which is correct?

A: All walls are to be 16” centers.

Q: Is the bid to include electrical?

A: No. The City is responsible for electrical and the vendor will not be held liable for the completion date. We are hoping to get it completed by the end of July as the present building is coming down in July.

There are no further changes to this bid.