

ADDENDUM NO. 2

December 28, 2009

Krech Ojard & Associates, PA – Engineers & Architects
227 West First Street, Suite 200, Duluth, MN 55802
KOA Project No. 061153

PROJECT:

**Vehicle Storage Facility at the Tree Farm Site for the City of Duluth
Project No. OT-0709
Bid Number 9-18DS (1)
KOA Project No. 06-1153**

This Addendum No. 2 issued December 28 2009 added to and shall become a part of the specification and drawings dated December 3, 2009. Bidders shall acknowledge receipt of addendum on their bid form.

Bid due Tuesday, January 5, 2010 @ 2:00 P.M. CDT

DRAWINGS:

Delete all reference to Bituminous Apron. Apron in front of building to be concrete as shown in detail 4/A3.

Include in Bid Cost to install an 8' 0" wide x 14' 0" long concrete pad for propane tank. Also provide four pipe bollards as shown in detail 4/A2. Concrete pad shall be 4 inch thick reinforced with #4 bars 12' on center each way. Pad to have 12 inch x 12 inch thickened edge reinforced with (2) #4 bars continuous.

Steel pipe for all bollards shall be ASTM A53 Schedule 40.

PRODUCT APPROVALS:

Sectional Doors: Wayne Dalton TS 150

Painting: Diamond Vogel Paints

Pre-Engineered Metal Building: Behlen Manufacturing Co.
Nucor Building Systems

ADDENDUM NO. ME-2

DATE: December 22, 2009

PROJECT: VEHICLE STORAGE FACILITY - TREE FARM SITE
DULUTH, MINNESOTA

ARCHITECTS: KRECH, OJARD & ASSOCIATES
227 WEST FIRST STREET, ROOM 200
DULUTH, MINNESOTA 55802
PHONE (218) 727-3282
FAX (218) 727-1216

ENGINEERS: FOSTER, JACOBS & JOHNSON, INC.
345 CANAL PARK DRIVE, SUITE 200
DULUTH, MINNESOTA 55802
PHONE (218) 722-3060
FAX (218) 722-1931

This Addendum is issued to modify, interpret or supplement the Bidding Documents and is hereby made a part of the Bidding Documents. Please attach this Addendum to the Project Manual in your possession and insert the number of this Addendum in the blank space provided in the Bid Form.

DRAWINGS:

E1: Delete SG-1 (sliding gate) from the Motor and Equipment Schedule.

SUBSTITUTIONS:

The following manufacturers and their products have been approved for substitution; however, such prior approval in no way relieves the supplier from complying in every respect with the requirements of the Bidding Documents.

<u>Section</u>	<u>Product</u>	<u>Manufacturer</u>
Electrical	Luminaires	Type A, A1, & B - Columbia Type E & EM - Dual Lite

End of Addendum ME-2