

**SECTION 00911**

**ADDENDUM NUMBER 2**

**PARTICULARS**

**1.01 DATE: October 19, 2009**

**1.02 PROJECT: District Chilled Water Extension to US Courthouse, 515 W. First St., Duluth, MN 55802.**

**1.03 PROJECT NUMBER: 09-0481**

**1.04 OWNER: City of Duluth (Duluth Steam Coop District #1).**

**1.05 ENGINEER: Andrew Engineering Ltd.**

**TO: PROSPECTIVE BIDDERS**

**2.01 This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated August 17, 2009, with amendments and additions noted below.**

**2.02 Acknowledge receipt of this Addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.**

**CHANGES TO THE PROJECT MANUAL**

**3.01 SECTION 15085.3.03**

- A. Clarification: Subparagraph A refers to heating and cooling heat exchangers.
- B. Add as sub paragraph B the following: Filter package SF-1; all piping and the body of the filter are to be insulated. Provide a removable insulation cover on the filter basket complete with flexible fabric

**CHANGES TO THE PROJECT DRAWINGS**

**4.01 Drawing M2.0**

- A. Hydronic Filter Schedule: Change unit number from HX-1 to SF-1
- B. Clarification: SF-1 will be installed in the location indicated by plan note 6.
- C. Clarification: Only the work shown in the "cloud" is included in this project.

**END OF SECTION**