SECTION 16075

ELECTRICAL IDENTIFICATION

PART 1 GENERAL

1.01 SECTION INCLUDES

A. Wire and cable markers.

B. Conduit markers.

PART 2 PRODUCTS

2.01 MANUFACTURERS

A. Brady Corporation: www.bradycorp.com.

B. Seton Identification Products: www.seton.com/aec.

C. HellermannTyton: www.hellermanntyton.com.

2.02 WIRE MARKERS

A. Description: Cloth or tape type wire markers.

B. Locations: Each conductor at panelboard gutters, pull boxes, outlet boxes, and junction boxes each load connection.

C. Legend:
   1. Power and Lighting Circuits: Branch circuit or feeder number indicated on drawings.
   2. Control Circuits: Control wire number indicated on schematic and interconnection diagrams on drawings.

2.03 CONDUIT MARKERS

A. Location: Furnish markers for each conduit longer than 6 feet.

B. Spacing: 20 feet on center.

PART 3 EXECUTION

3.01 PREPARATION

A. Degrease and clean surfaces to receive nameplates and labels.

3.02 INSTALLATION

A. Install nameplates and labels parallel to equipment lines.

END OF SECTION