

ADDENDUM #1
WESTGATE BOULEVARD FLOOD DAMAGED UTILITY AND STREET REPAIRS
CITY OF DULUTH
PROJECT 1111
BID No. 12-0486
August 23, 2012

NOTICE

This Addendum is issued to modify, explain or correct the original drawings, specifications and/or previous addenda and is hereby made a part of the Contract Documents. Please note receipt of this Addendum on the Request for Bid. The Bid Opening Date , August 29, 2012, 2:00 p.m. remains the same.

The following clarification/direction shall be considered when bidding the job. No plan revisions will be issued at this time.

1. Along the face of the slope, as shown on sheet G-3, geotextile shall be Type VI geotextile per spec 3371. Geotextile fabric within the roadway section shall be Type V as shown on sheet G-8. Exhibit A, Line Item No. 9, Geotextile Fabric should read "Geotextile Fabric, Type V & VI".
2. Poly fittings per the City of Duluth's Standard Construction Specifications in lieu of mechanical joints are acceptable to be used to install the 45-degree bends in the HDPE water main. These fittings shall be fabricated, not molded. A mechanical joint will be required for the connection to the existing piping.
3. Geogrid shall be manufactured by Tensar International, Biaxial Geogrid BX1100 or equal. Installation techniques shall be per manufacturer's specifications and recommendations.

END OF ADDENDUM