



CITY OF DULUTH
PURCHASING DIVISION
Room 100 City Hall
411 West First Street
Duluth, Minnesota 55802-1199
218/730-5340 218/730-5922 FAX
purchasing@duluthmn.gov

Addendum # 1
File # 16-0587
Hartley Park Parking Lot Improvements

This addendum includes the following revisions, additions and changes to the scope of work for the above referenced project. Bidders are requested to include the items listed in this addendum as part of their Bid.

- 1) Hartley Nature Center, Fairmont Street, and North Road, should all have B618 curb & gutter. Hartley Road should have B624 curb and gutter.
- 2) Bio-logs should be wood fiber.
- 3) Silt fence should be Heavy Duty.
- 4) 12" culvert should be dual-walled HDPE with smooth inner wall.
- 5) All saw-cutting of asphalt surfaces, in all projects, should be an alternate.
- 6) Relocation of the street light in Project #4, North Road, should be an alternate, not a Miscellaneous item.

Also, a revised bid tab for the 4 projects in Word format has been posted to the website.

Please acknowledge receipt of this Addendum by initialing and dating Addendum #1 on the bid form.

Posted: October 11, 2016