



CITY OF DULUTH
PURCHASING DIVISION
Room 100 City Hall
411 West First Street
Duluth, Minnesota 55802-1199
218/730-5340
purchasing@duluthmn.gov

Addendum # 2
File # 17-0437
Morgan Park Community Center Upgrades

This addendum serves to notify all bidders of the following:

1. Where plans and specs call for “vertical metal siding, board and batten” please bid Firestone Uniclاد UC-501 prefinished steel 24 gauge.
2. Where plans and specs call for “vented metal soffit” please bid Firestone Uniclاد UC-750 in 0.32 aluminum.
3. Where plans and specs call for “insulated metal panels” near storefront or other glazing systems (detail 3 sheet A401) please substitute details from detail 6 sheet A400.
4. Where plans show “Insulated metal panel board” below wrapped LVL fascia (detail 3 sheet A400) please use polyisocyanurate or other rigid foam board with metal wrap.
5. To clarify:
 - a. Phase 1 includes the roof, the clerestory windows and any related details.
 - b. Phase 2 includes ground level windows and doors listed on plans.

Please acknowledge receipt of this Addendum by initialing and dating Addendum #2 on the bid form.

Posted: June 26, 2017