



CITY OF DULUTH
PURCHASING DIVISION
Room 100 City Hall
411 West First Street
Duluth, Minnesota 55802-1199
218/730-5340 218/730-5922 FAX
purchasing@duluthmn.gov

Addendum #4
File # 17-0437
Morgan Park Community Center Upgrades

This addendum serves to notify all bidders of the following changes to the solicitation documents:

Substitute Firestone Clad-Gard R Metal Roofing Underlayment for two (2) layers listed in the "SIP Roof System" assembly as shown in Detail 1 Sheet A400 upper right:

1. Directly on top of existing nail base panel to form the primary air barrier / vapor retarder. Note that this layer must connect to existing assemblies at perimeter to create continuity.
2. On top of the SIP panels and directly under the standing seam steel roofing.

Install according to manufacturer's recommendations. Lap both layers shingle style and flash and seal all penetrations to create, air, water and vapor tight continuous layers.

Please acknowledge receipt of this Addendum by initialing and dating Addendum #4 on the bid form.

Posted: July 3, 2017