



**CITY OF DULUTH**  
PURCHASING DIVISION  
Room 120 City Hall  
411 West First Street  
Duluth, Minnesota 55802-1199  
218/730-5340  
[purchasing@duluthmn.gov](mailto:purchasing@duluthmn.gov)

**Addendum 2**  
**Solicitation 18-0635**  
**Vehicle Barriers on Library/Depot Upper Parking Lot**

This addendum serves to notify all bidders of the following changes to the solicitation documents:

This addendum includes the specification changes, changes to drawings and addresses questions received.

1. **Changes to Specifications:**  
Section 05 12 00 Structural Steel:  
Part 2.01 H. Guardrail: Omit the wording: "Class B – 10 Gauge (0.135" nominal thickness)" and replace with: "Class A – 12 gauge".
2. **Questions and Answers:**  
Q: Will ACI Adhesive Anchor Certification be required for installing the anchors?  
A: No.
3. **Changes to Drawings:** None.
4. **Substitution Requests:** None.
5. **Clarification:** A 5% bid surety check or bid bond is required on this project. If submitting a paper bid, you must contact the Purchasing office for the appropriate forms to submit. Electronic bids via [www.bidexpress.com](http://www.bidexpress.com) are preferred. If bidding electronically, paper bid sureties are still acceptable, but must be received in Purchasing prior to the bid deadline. Email bids or bid sureties are not acceptable.

Please acknowledge receipt of this Addendum by checking the acknowledgement box in the Bid Express solicitation.

Posted: October 12, 2018