





Purchasing Division
Finance Department
Room 120
411 West First Street
Duluth, Minnesota 55802

 218-730-5340
 purchasing@duluthmn.gov

Addendum No. 5
Solicitation #25-0431

Scope 1: Coal Burner to Natural Gas and Fuel Oil Burner: Balance of Plant and Fuel Oil System

This addendum serves to notify all bidders of the following changes to the solicitation documents:

Below are questions asked by contractors and their subsequent answers:

1. Question: What is the duct size for the install location of the new FD fan damper?
Answer: Approximate dimensions of existing ductwork for installation downstream of the FD fan are 4'-6" x 3'-0". Contractor to verify final location for installation and exact dimensions in field.
2. Question: What is the duct size for the install location of the new economizers on BLR 1 & 4?
Answer: Approximate dimensions of existing ductwork for installation downstream of the ID fan are 6'-0" x 4'-0". Contractor to verify final location for installation and exact dimensions in field.
3. Question: Is an expansion joint to be installed at these locations of the new FD fan damper and economizer?
Answer: Only if it is required to prevent stress on Contractor provided equipment.

Please acknowledge receipt of this Addendum by checking the acknowledgement box within the www.bidexpress.com solicitation.

Posted: **July 29, 2025**