

ADDENDUM NO. 1

July 13, 2011

for

**CITY OF DULUTH PARKING RAMP LIGHTING
DEPOT AND CONEY ISLAND RAMPS**

Depot Ramp – 6th Avenue West & Michigan Street
Coney Island Ramp – 110 West First Street
Duluth, Minnesota

Owner:

CITY OF DULUTH
1532 West Michigan Street
Duluth, MN 55806

Architects/Landscape Architects/Engineers/Interior Designers:

ARCHITECTURAL RESOURCES, INC.
704 East Howard Street
Hibbing, MN 55746
218/263-6868 (218/722-6803 fax)
ARI Project # 11-027

This addendum shall be appended to and take precedence over and become a part of the plans and specifications.

DRAWINGS:

1. Sheet E0.4 lower level Coney ramp near entrance shows two rows of three lights. Second row should have four being removed (see attached drawings).
2. Sheet E1.4 upper level Coney ramp. Type “C” fixtures that will replace recessed lights being removed should be: “Mount to avoid interference with door swing and provide best lighting possible for surrounding area. Patch existing canopy to match existing finish and provide and extend conduit and wire when required.”
3. Sheet E1.4 lower level Coney ramp. Type “E” fixture at garage entrance contains existing photo cell. Existing photo cell to be removed. Provide and install new photo cell.

APPROVALS:

<u>Item</u>	<u>Manufacturer</u>
Light Fixture Type “A”	Envirogreen, Premier
Light Fixture Type “B”	Spaulding, GE
Light Fixture Type “C”	Premier
Light Fixture Type “D”	Spaulding
Light Fixture Type “E”	Envirogreen, Kenall
Light Fixture Type “F”	Lumca, GE
Light Fixture Type “G”	Not Used

ATTACHMENTS:

1. Addendum #1 Demolition Plan & Addendum #1 Plan dated July 13, 2011

END OF ADDENDUM NO. 1