



DULUTH AIRPORT
AUTHORITY

DULUTH
INTERNATIONAL
AIRPORT
DULUTH, MN

NEW PASSENGER
TERMINAL

CONSULTANTS

Interior Architects:
SJA ARCHITECTS
11 E Superior Street, Ste 540, Duluth MN 55802
TEL: (218) 724-6578 / FAX: (218) 724-6717

Structural Engineer:
MBJ CONSULTING ENG
501 Lake Avenue South, Suite 200, Duluth MN 55802
TEL: (218) 722-1056 / FAX: (218) 722-9308

ME/PEP Engineer:
COSENTINI ASSOCIATES INC.
1 South Wacker Drive, 37th Floor, Chicago IL 60606
TEL: (312) 201-7488 / FAX: (312) 201-0031

Baggage Handling Systems Consultants:
BNP ASSOCIATES INC.
801 East Ridge Office Park, Suite 103, Danbury CT 06810
TEL: (203) 792-5000 / FAX: (203) 792-4900

Landscape Consultants:
APPOLO DESIGN
2432 East 7th Street, Duluth MN 55812
TEL: (218) 591-5079

ENGINEER CERTIFICATION
I hereby certify that the engineering plans, specifications, and reports prepared by me or under my direct supervision and that I am a duly licensed Professional Engineer under the laws of the State of Minnesota.

Print Name: Douglas C. Mass

Signature: *Douglas C. Mass*

Date: 08/16/10 Reg. No.: 21067

REVISIONS

NO.	DESCRIPTION	DATE
1	ADDENDUM 1	6.11.10
3	CONFERENCE SET PERMIT REVISIONS BUILDING PERMIT 100% REVIEW BID PACKAGE 2A	7.23.10 8.16.10 12.17.10 1.24.11
Δ	BPA ADDENDUM 2	2.25.11

DATE ISSUED: 02-25-11

REVIEWED BY: XXX

DRAWN BY: JK

DESIGNED BY: JK

AEP PROJECT NUMBER

213-1882-091

SHEET TITLE

CANOPY
LIGHTING PLAN

SHEET NUMBER

E118

BID PACKAGE 2A
ADDENDUM 2

- NOTES:
1. CANOPY LIGHTING FIXTURES ARE CONNECTED TO PANEL "LP-1A".
 2. UTILIZE EXISTING EMPTY CONDUIT (INSTALLED IN UNDERGROUND PACKAGES) FOR CIRCUITRY ASSOCIATED WITH CANOPY LIGHTING.
 3. PROVIDE HEAT TRACE CABLE IN CANOPY STORM PIPES - SEE DWG E402 FOR SPECIFICATION. PROVIDE 277V/1P LOCAL DISCONNECT FOR EACH HEAT TRACE CIRCUIT. CONNECT CIRCUITS TO PANEL "PP-1A".