

Medical Ramp

The Medical Ramp is located on the corner of E. 1st Street and N. 3rd Ave E. The ramp provides a skyway route to the adjacent St. Mary's Medical Center and to the Sheraton Hotel. Accessible parking spaces were provided at the time of construction.

Parking- Medical

Accessibility Review

Location JQP # / Item #	Solution / Comments	Qty	Unit Cost	Total Cost	Priority	Estimated Compl. Date	Person Responsible	Actual Compl. Date	Actual Cost
----------------------------	---------------------	-----	-----------	------------	----------	--------------------------	-----------------------	--------------------------	----------------

Parking- Aisles

05H 16735	<p>Stripe to provide an accessible parking stall that is 8' wide with an adjacent 8' access aisle. It is preferred that the access aisle be located on the passenger side of the vehicle. MN 1341 502.4.2</p> <p><i>Currently only 3 parking spaces have 8' wide aisles. All other accessible parking spaces have 5' wide aisles. Note: if this ramp was constructed prior to 2007 it complied with the requirements at the time of construction. Photo 1.</i></p>	8	\$150	\$1,200	4				
-----------	--	---	-------	---------	---	--	--	--	--

Parking- Quantity

05A 16734	<p>Stripe an appropriate number of accessible parking stalls and provide appropriate permanent signage. IBC 1106.1</p> <p><i>Based on a total parking quantity of 595, a total of 12 accessible parking spaces are required. Currently 11 spaces have been designated as accessible, designate 1 additional parking space. Note: This parking ramp serves medical facilities, the quantity of accessible parking spaces required is calculated differently for certain types of medical facilities. (A greater quantity of accessible parking spaces may be required based on MN1341 1106.3 and 1106.4.)</i></p>	1	\$400	\$400	4				
-----------	--	---	-------	-------	---	--	--	--	--

Vestibules

20M 16736	<p>Provide a smooth surface at the bottom (within 10" of the floor) of the door, that extends the full width of the door. ICC / ANSI 404.2.9</p>	7	\$50	\$350	4				
-----------	--	---	------	-------	---	--	--	--	--

Priority # 4 Total \$1,950

Transition Plan - (location/priority)



Photo 1: Currently 3 of the parking spaces provide 8' aisles. The other 8' parking spaces have 5' wide aisles. (Complied at time of construction.)