

Hartley Nature Center

Activities / Amenities

- Picnic
- Portable Toilets
- Nature Center Building
- Trails
- Parking

Picnic

Picnic

There are 8 picnic tables, including 4 with knee and toe clearance, scattered in the grass near the nature center building.

JQP, Inc. Recommends

Priority 3- Relocate the tables to an accessible location (or create an accessible route and accessible clear ground space at the current location). *Recommended based on Draft Accessibility Guidelines for Outdoor Developed Areas 1011.2*



Trails (Hiking and Cross Country Skiing)



Superior Hiking Trail Kiosk

The kiosk with information about the Superior Hiking Trail is located near the accessible route to the building, but not on the route (and the angle and font size does not allow viewing from the route). The lid of the map box is currently at 54".

JQP, Inc. Recommends

Priority 3- Relocate the sign to an accessible route or create an accessible route to the sign. *Recommended based on National Park Service Interpretive Media Guide.*

Priority 3- Lower the map box to 48" maximum.
ADA 308



Signs

There are kiosks and trail head signs that provide maps and information about the trails.

JQP, Inc. Recommends

Priority 2- Include information on the trail head signs about features of accessibility on the trail, including: length, surface, width, slope and cross slope. *Recommended based on Draft Accessibility Guidelines for Outdoor Developed Areas 1017.11*



Trails

There are more than 10 miles of developed trails in Hartley Park, including segments that comply with the *Draft Accessibility Guidelines for Outdoor Developed Areas*.

JQP, Inc. Recommends

Priority 3- At such time trails are created, altered or rerouted, provide accessibility to the maximum extent feasible. *Recommended based on Draft Accessibility Guidelines for Outdoor Developed Areas F247.1, 1017*

Portable Toilets

Portable Toilets

There is currently 1 portable toilet located in the parking lot. The portable toilet is not an accessible style.

JQP, Inc. Recommends

Priority 2- Provide a minimum of 1 larger/accessible style portable toilet. *ADA 213.2 Exception 3*

Note: Accessible toilets rooms are provided in the nature center building, but the building is not open at all hours the park is open to the public.



Nature Center Building

Nature Center Building

JQP, Inc. prepared a detailed report of the Hartley Nature Center building, it has been included in the facilities report.

Parking

Parking

There are 2 parking spaces designated as accessible. Signs are provided, but the parking spaces are not currently striped.

JQP, Inc. Recommends

Priority 2- Stripe the accessible parking spaces to provide an 8' wide minimum space with an 8' wide minimum aisle. (Note: 2 spaces can share an aisle.)
MN1341 502.4.2

