

# Leif Erikson Park

## **Activities / Amenities**

- |                                       |  |
|---------------------------------------|--|
| <input type="checkbox"/> Amphitheater | <input type="checkbox"/> Overlook        |
| <input type="checkbox"/> Trail        | <input type="checkbox"/> Portable Toilet |

Parking is available on the street or shared with the Rose Garden.

## **Amphitheater**

### **Seating**

Permanent seating is not provided. There is open lawn seating. An accessible hard surface route (the Lakewalk) is provided up to the edge of the grass (opposite the stage) but does not connect to the stage.

### **JQP, Inc. Recommends**

**Priority 2-** Create an accessible route to the lawn seating area and the stage. ADA 221.5, 206.2.6



### **Route**

The route to the stage currently exceeds 5% (and exceeds 8.33% for a route without a handrail). Barriers have been added at the top to discourage bikes, skateboards and rollerblades due to the steep slope.

### **JQP, Inc. Recommends**

**Priority 2-** Create an accessible route to the stage. ADA 206.2.6



### **Stage**

There is not currently an accessible route onto the stage of the amphitheater.

### **JQP, Inc. Recommends**

**Priority 2-** Create an accessible route onto the stage. ADA 206.2.6



## Overlooks



### Route

There is an overlook (viewing area) along the shore. An accessible route is not currently provided to the overlook.

### JQP, Inc. Recommends

**Priority 3-** Create an accessible route to the overlook. *Recommended based on Draft Accessibility Guidelines for Outdoor Developed Areas F246.2*

## Trail

The Lakewalk runs along the north boundary of Leif Erikson Park.

### Dog Bags

There is currently a big dispenser provided for the collection of dog droppings. The dispenser is currently located approximately 3' from the accessible route.

### JQP, Inc. Recommends

**Priority 3-** Add an accessible route to the dog bags or relocate to an accessible location. ADA 206.2.2



## Portable Toilet



### Portable Toilet

There is currently a portable toilet positioned opposite the stage of the amphitheater. The portable toilet is not an accessible style and is not located on an accessible route.

### JQP, Inc. Recommends

**Priority 3-** Provide an accessible portable toilet unit, located on an accessible route.

Note: This toilet room is provided by a church and is for church use only. (There is a padlock and sign on the door.)