



CITY OF DULUTH
PURCHASING DIVISION
Room 120 City Hall
411 West First Street
Duluth, Minnesota 55802-1199
218/730-5340
purchasing@duluthmn.gov

Addendum 2
File 19-99643
Stone Materials for Canal Park Storm Damage Repair

This addendum serves to notify all bidders of the following changes to the solicitation documents:

1. The pre-bid meeting sign-in sheet has been uploaded to the Bid Express solicitation and the City's Purchasing website (<https://www.duluthmn.gov/purchasing/bids-request-for-proposals/>).
2. Can the successful bidder supply the rock from multiple sources? Yes, as long as a color sample is submitted from each source and each source passes the listed testing requirements. The on-site geologist requirement applies to each sourced location.
3. The City is executing a separate contract to install an access road, traffic control, fencing, and removal of boardwalk for the purposes of hauling stone.
4. Snow removal of the carriage path is performed by Park Maintenance staff. Snow removal within the storage area will be the responsibility of the successful bidder and is considered incidental to the contract.
5. The allowed stone specific gravity ratio is 2.65 to 3.1 (stone density ranging from 165.4 to 193.4 pounds/cubic foot). If the bidder supplies a higher specific gravity (3.2, or a density of 199.7 pounds/cubic foot), this is acceptable, if the stone meets all the other testing requirements provided in the project specifications.

Please acknowledge receipt of this Addendum by checking the acknowledgment box within the www.bidexpress.com solicitation.

Posted: October 28, 2019