



**Purchasing Division**  
*Finance Department*  
Room 120  
411 West First Street  
Duluth, Minnesota 55802

218-730-5340  
purchasing@duluthmn.gov

**Addendum 4**  
**Solicitation 20-99363**  
**Canal Park Lakewalk & Shoreline Restoration**

This addendum serves to notify all bidders of the following changes to the solicitation documents:

1. The bid deadline has been extended to **Thursday, May 14, 2020 at 2:00 pm.**
2. On sheet 38 of the plans, Detail 03 "Boardwalk Typical Detail – Plan", delete #8 x 3" DECKING SCREWS and add #10 x 3" DECKING SCREWS.
3. The City requests alternate pricing for schedule 80 PVC conduit in place of rigid metal conduit relating to:
  - Sheet E 000
  - Section 26 0500
  - Work Results for Electrical
  - C. Conduit and Boxes
  - 1. Underground and above ground conduit shall be rigid metal conduit (RMC) unless otherwise noted.

For clarification, the price entered for the deduct alternate on the bid form must reflect the savings to the City should the alternate be selected (i.e., if rigid metal conduit costs \$5,000, and the PVC costs \$4,000, the amount to be entered in the deduct alternate is \$1,000).

Please acknowledge receipt of this Addendum by checking the acknowledgment box within the [www.bidexpress.com](http://www.bidexpress.com) solicitation.

Posted: **May 11, 2020**