

## Purchasing Division Finance Department

Room 120 411 West First Street Duluth, Minnesota 55802



## Addendum 2 Solicitation 23-99641 Shoreline Rehabilitation between 3<sup>rd</sup> Ave. E. and 4<sup>th</sup> Ave. E.

This addendum serves to notify all bidders of the following changes to the solicitation documents:

The following questions have been asked and are answered in *Italics* below:

- 1. Could any portion of the temporary shoring be left in place?
  - a. Yes, with the following restrictions:
    - i. Any temporary shoring that is left in place cannot impact future replacement of existing infrastructure (sanitary sewer, storm sewer, etc.)
    - ii. Any temporary shoring that is left in place cannot encroach on the Railroad Right of Way (assume lakeside of existing black fencing that protects the public from the railroad).
- 2. Can tieback anchors be used for the temporary shoring?
  - a. Yes; however, the Contractor would be liable for any damage to existing infrastructure. There is a large sanitary forcemain that is of significant concern under the Lakewalk which tieback anchors will likely be in conflict with.

Please acknowledge receipt of this Addendum by checking the acknowledgement box within the <a href="https://www.bidexpress.com">www.bidexpress.com</a> solicitation.

Posted: September 26, 2023