

Purchasing Division Finance Department

Room 120 411 West First Street Duluth, Minnesota 55802



Addendum 1 Solicitation 24-99375 Eng Svcs for Junction Avenue/St. Marie Street Reconditioning

This addendum serves to notify all bidders of the following changes to the solicitation documents:

Answers to questions received as of 3/21/24 are indicated in *red*:

- 1. Is the City able to provide access to GIS mapping of storm water system if available? The City has GIS mapping of the storm water system. Contact the Engineering Front Office to request the files.
- 2. Is the City able to provide PDF mapping of storm water system?

 A pdf of the storm water system is attached and highlighted to show the areas needing inspection.
- Under general project scope the numbering is off- is it okay to correct this in our proposal

Yes, I didn't realize that the rest weren't tied together.

- 4. Under Scope of Services the proposal identifies
 - 1- Initial Site Visit and Consultations
 - 2- Public Participation
 - 3- Reconnaissance, Field Surveys & Geotechnical Exploration
 - 5- Plans & Specifications
 - 6- Cost Estimate
 - 7- Project Bidding

Is the numbering off or is there an item 4- that we are missing from RFP?

The numbering is off, again something was changed during drafting and I had assumed they would update.

- 5. What is the purpose of the storm sewer televising?
 - The City would like to have a condition assessment to repair pipes that are in danger of failing over the life of the project during the project instead of having to dig in a new road.
- 6. Which storm sewer structures need to be inspected?
 - Inspect all structures within the project in order to plan for any needing replacement or reconditioning. Structures within the reconstruction sections will be replaced during that work, but invert elevations will be needed for the replacements.
- 7. What is the existing pavement section?
 - The record drawings show a 7.25" bituminous surface over 8" of class V.
- 8. Will the storm sewer items be non-participating?

 It is expected that State Aid will cover at least a portion of the storm sewer items and the hydraulic

report will need to be reviewed by them.

Please acknowledge receipt of this Addendum by including a copy of it with your proposal. The pages included will not count toward any page limitation, if any, identified in the RFP.

Posted: March 22, 2024





411 W 1st St, DULUTH, MN 55803 PHONE: (218) 730-5000 www.duluthmn.gov

Source: City of Duluth Author: wpalokangas Date: 3/20/2024

Junction Ave/West St. Marie Storm Sewer System

City of Duluth, MN



