



Purchasing Division
Finance Department
Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum No. 1
Solicitation 25-0275
DECC Hot Water Pipe Replacement

This addendum serves to notify all bidders of the following changes to the solicitation documents:

Questions and Responses:

1. Will DES be supplying the generator the welder (joint fusion machine) needs to be wired to?
 - a. DES will provide the generator for the insulation joint fusion machine. The generator will be at DES's storage area (1400 Railroad Street) by April 28th.
2. How many sets of clamps are coming with the welder?
 - a. Two sets of insulation joint clamps will be provided with the joint fusion machine. This will allow the insulating contractor to prepare a joint ahead of the current joint being fused.

Changes/Clarifications:

1. Please provide a breakdown of the lump sum bid into two phases:
 - a. Phase 1: Railroad Street crossing, as shown on drawing HW2.
 - b. Phase 2: The remaining work in the DECC parking lot, as shown on drawing HW1.

Please acknowledge receipt of this Addendum by checking the acknowledgement box within the www.bidexpress.com solicitation.

Posted: **March 19, 2025**