

**Purchasing Division** Finance Department

Room 120 411 West First Street Duluth, Minnesota 55802 **()** 218-730-5340

purchasing@duluthmn.gov

# Addendum 2 Solicitation 24-99349 Lakewood Water Treatment Plant Power Improvements - Generators

This addendum serves to notify all bidders of the following changes to the solicitation documents:

• Please see the attached document

Please acknowledge receipt of this Addendum by checking the acknowledgement box within the <u>www.bidexpress.com</u> solicitation.

Posted: March 19, 2024



### ADDENDUM #2 24-99349 Lakewood WTP PI - Generators GENERATORS - LAKEWOOD WATER TREATMENT PLANT POWER IMPROVEMENTS CITY OF DULUTH PROJECT 00616197 MARCH 13, 2024

Page 1 of 1

#### CERTIFICATION

I hereby certify that this document was prepared by me or under my direct supervision and that I am a duly Licensed Professional Engineer under the laws of the State of Minnesota.

Print Name: <u>Scott Chilson</u>
Signature: Satt R. Chilan
5

Date: <u>3/14/2024</u>

License #: <u>44287</u>

# NOTICE

This Addendum is issued to modify, explain, or correct the original drawings, specifications and/or previous addendums and is hereby made a part of the Contract Documents. The bid date remains unchanged.

## PROJECT MANUAL

<u>APPENDIX E – Engineering Technical specifications</u>

DIVISION 26 Electrical

SECTION 26 32 10 Generators

26 32 10 Paragraph 1.04 Description of Work, A. 1.

**CLARIFCATION**: it is the intent that a load bank will be connected to the 2.4V buss for the express purpose of testing and proving the closed transition control, open transition control, and load shedding/sharing of the parallel generator units. Load banking for the individual units on the 480V side may be conducted at the factory or on site.

26 32 10 Paragraph 2.10 Shoreline Outdoor Cold Weather-Protective Housing, A. 1.

**REPLACE** with the following:

"1. Sound pressure shall be 75 dBA or less as measured at 23 feet from enclosure at full load."

## END OF ADDENDUM