



Purchasing Division
Finance Department
Room 120
411 West First Street
Duluth, Minnesota 55802

218-730-5340
purchasing@duluthmn.gov

Addendum 2
Solicitation 24-99350
Lakewood Water Treatment Plant Power Improvements - Transformers

This addendum serves to notify all bidders of the following changes to the solicitation documents:

- Please see the attached document
- The following questions have been asked and are answered in *italics* below.

Questions

1. Will you be accepting refurbished transformers for this solicitation?
a. *No, we will only be accepting new transformers*
2. Will you accept transformers built outside of the United States that are manufactured by IEEE, Department of Energy, and NEMA standards?
a. *The transformer must be equal to the named manufactures and fulfill the specification requirements. If you believe your offering is equal, please explain with documentation how it is equal to the listed products. Note the transformers must comply this the NEC since this is not a utility owned equipment.*

Please acknowledge receipt of this Addendum by checking the acknowledgement box within the www.bidexpress.com solicitation.

Posted: **March 19, 2024**




ADDENDUM #2
24-99350 Lakewood WTP PI - Transformers
TRANSFORMERS - LAKEWOOD WATER TREATMENT PLANT POWER IMPROVEMENTS
CITY OF DULUTH
PROJECT 00616197
MARCH 13, 2024

Page 1 of 1

CERTIFICATION

I hereby certify that this document was prepared by me or under my direct supervision and that I am a duly Licensed Professional Engineer under the laws of the State of Minnesota.

Print Name: Scott Chilson

Signature: 

Date: 3/15/2024 License #: 44287

NOTICE

This Addendum is issued to modify, explain, or correct the original drawings, specifications and/or previous addendums and is hereby made a part of the Contract Documents. The bid date remains unchanged.

PROJECT MANUAL

APPENDIX E – Engineering Technical specifications

DIVISION 26 Electrical

SECTION 26 12 19.01 Medium Voltage Transformers

26 12 19.01 Paragraph 1.03 Description of Work, B. 1.

REPLACE with the following:

“All equipment, materials, and appurtenances provided under this contract shall be new. Refurbished, renewed, and used materials shall not be accepted.”

END OF ADDENDUM