



**Addendum 1**  
**Solicitation # 26-99395**  
**PROJECT #2360 – Water Tower Reconditioning – Proctor & Bayview**

This addendum serves to notify all bidders of the following changes to the solicitation documents:

**Bidding Questions:**

- 1) Regarding the Temporary Pressurized Water System for the Proctor Tower, what is the average gallons per day (GPD) and are the pumps that supply the zone of VFDs?

Response: This pumps the feed the Proctor Tower are not on VFDs, the two pumps run one at a time and each pump at a rate of 1300 GPM. Average water usage in this zone is approximately 436,000 GPD.

- 2) Are water hydrants within the vicinity of each site? Will there be a charge for water usage on the project?

Response: Yes, there are water hydrants in the vicinity of each site. The standard water hydrant permit will still be required but permit fee and usage fees will be waved for this project. No charge for using City of Duluth water on this project.

- 3) Is the project tax exempt?

Response: Yes, the project is tax exempt.

Please acknowledge receipt of this Addendum by checking the acknowledgement box within the solicitation at [www.bidexpress.com](http://www.bidexpress.com).

Posted: 4/10/2026