



FOR IMMEDIATE RELEASE
City of Duluth Fire Department

411 West First Street, Duluth, Minnesota 55802
218-730-4400 | www.duluthmn.gov | John Strongitharm, Fire Chief

For more information contact the Fire Department at 218-730-4391



DATE: 02/14/2014
NATURE OF INCIDENT: Structure Fire at NorShor Theatre
CASE NO.: 14-001362
INCIDENT DATE :02/14/2014
INCIDENT TIME: 0426
INCIDENT LOCATION: 211 E. Superior St
SUBJECT: Structure Fire at NorShor Theatre
BY: Assistant Chief's Office

At 0426 this morning the Duluth Fire Department was dispatched to a automatic fire alarm at the Norshor Theatre. Upon arrival crews found live smoke inside the building, and smoke venting from an upper story window. A full alarm response was requested and crews from downtown, Lincoln Park and UMD responded. The fire was contained to a single room in the upper levels above the main theatre. The cause of the fire is determined to be a failed blower motor for the buildings heating system. Fire was contained to the room, however there was moderate smoke throughout. Damage estimates are set at \$15,000.