

Purchasing Division Finance Department

Room 120 411 West First Street Duluth, Minnesota 55802



Addendum # 1 Solicitation 24-99390 Chester Park Drive Alley #2102

This addendum serves to notify all bidders of the following changes to the solicitation documents:

DRAWINGS

There are no revisions to the drawings under this addendum.

SPECIFICATIONS

1. Add SP-29: (2503) Pipe Sewers - Gravity:

Connection to the existing storm sewer shall be made by connection to the existing storm sewer piping outside of the storm manhole structure. Pipe shall be cut cleanly approximately 5 feet from the existing structure and connection with a flexible gasketed connector shall be constructed. Pay item "Connect to Existing Storm Sewer" shall be measured on the basis of each (EA) and include all labor, materials, equipment and incidentals to complete the connection to the existing storm sewer and restore flow from the project to the existing stormwater system.

INFORMATION TO BIDDERS

- 1. The attendance sheet from the Pre-Bid Meeting is attached. Questions from the pre-bid meeting are as follows:
 - a. Do the lead service replacements go the whole way to the house? Yes. Service replacements will be done to and into the house per the plans and special provisions.
 - b. Is there documentation of the specific connection point in the house? Yes. Photos showing the inside of the homes and the connections points are included in the plans.
 - c. How will sewer services be installed after the CIPP liner?

 The sewer mains in the alley have been CIPP lined with services reinstated.

 Replacement of sewer services is addressed in the special provisions.

Please acknowledge receipt of this Addendum by checking the acknowledgement box within the www.bidexpress.com solicitation.

Posted: April 8, 2024

	Cheste	r Park Drive Alley Project
Pre-Bid Meeting - April 2, 2024 Sign-In Sheet Name/Contractor Email/Phone		
Afaine Jim Pucer	USA	USAINC et mattsi. Com 4342
	-	
	ž.	